



Water System Bacteriological Sampling Plan

I. System Information:

System or Facility Name: Baxter Mutual Water Co.

Service connections: 14
 (Number of residences and/or buildings served by the system)

Population: 24
 (Number of individuals served each day by system during busiest month)

Source(s): Well 01
 (List all water supply sources wells, springs, lakes, etc).

II. Routine Sampling Frequency

The water system must collect 1 routine sample at a frequency of once every quarter (three months)

III. Routine and Repeat Sampling Sites

* **Routine Sample Site No. 1:** 46200 (Zavala) or 46152 (Cooke) 125th St. East, as available

This site must be representative of the distribution system and shall not be designated as a water source (i.e., well, etc.). If this routine sample contains coliform bacteria, the water system must collect a set of repeat samples within 24 hours of being notified of the result. (If your routine sampling frequency is equal to or less than one sample per month, the repeat sample set must consist of at least 4 samples one of which a can be taken from the ground water source. If one or more of the groundwater sources were in at the time the Coliform positive sample was taken from the distribution system, a sample must be taken from each source and analyzed by method that enumerates for Coliform and E. coli (MPN).

Repeat Sample Set (No. 1)

Repeat sample site No. 1: Routine Sample Site No. 1
 (Collect one sample at the original routine sample site)

Repeat sample site No. 2: 46124 or 46125 or 46106 125th St. East, as available
 (Collect one sample within five connections upstream)

Repeat sample site No. 3: 12501 East Avenue H (near pumphouse)
 (Collect one sample within five connections downstream)

Repeat sample site No. 4: well head
 (Collect one sample from ground source)

* A routine sample site must be designated for each pressure zone or separate area served by the water system. The routine sample sites must be rotated such that they are all sampled on a regular basis. If this water system must designate more than one routine sample site, please do so on the following page.

Check one of the following:

- Only one routine sample site is necessary to adequately represent the system. Additional routine and repeat sample sites *are not* attached.
- This water system contains more than one pressure zone or separate area. Additional routine and repeat sample sites *are* attached.

IV. Sampling During The Month Following A Positive Sample

If one or more samples are positive for total coliform in a month, the water system is required to collect routine samples during the following month. These five samples can be collected over the course of the month or all on the same day. Please list the locations from which these extra samples would be collected:

- 1. Repeat site No. 1
- 2. Repeat site No. 2
- 3. Repeat site No. 3
- 4. Repeat site No 4
- 5. Storage Tank outlet

V. Map or Diagram

Attached.

VI. Personnel and Laboratory Notification

Sampler: Mary Wood
(Sample collection must be performed by a person trained in sample collection. Provide name of sampler.)

Laboratory: AVEK, 661-943-3201
(Provide the name and phone number of the certified lab doing your water analysis. Arrangement must be made for weekend and holiday analysis if needed.)

Notification: Laboratory to notify persons designated below within 24 hours whenever a sample is found to contain coliform bacteria:

1. <u>Mary Wood</u>	<u>661-266-7785</u>	<u>661-406-7271</u>
(Name)	(Daytime Phone #)	(Cell Phone #)
2. <u>Larry Gorden</u>	<u>661-946-1646</u>	<u>661-236-7803</u>
(Name)	(Daytime Phone #)	(Cell Phone #)

VII. Notification of the Department

The water system will notify the **Los Angeles County Public Health Department**, within 24 hours whenever a sample contains fecal coliform or *E. coli* bacteria or whenever a follow-up sample is positive. **In addition the system must direct the laboratory to immediately notify the Los Angeles County Public Health Drinking Water Program of any positive bacteriological result if the laboratory cannot make direct contact with designated contact person (in VI. above) within 24 hours.**

Richard Blood, Small Water System Coordinator: (916) 449-5632

Los Angeles County Department of Public Health – Drinking Water Program: (626) 430-5420

Los Angeles County Public Health: (213) 974-1234

Email: waterquality@ph.lacounty.gov

Submitted by: Larry Gorden Date 01/06/2012

KEEP A COPY OF THIS FORM FOR YOUR REFERENCE AND USE

ADDITIONAL INFORMATION

When responding to a laboratory report of bacterial contamination, keep in mind the following:

1. Coliform bacteria should not be present in drinking water and the presence of coliform indicates a potentially serious problem. Appropriate investigation should be performed immediately.
2. Check water system components such as water sources, filtration and/or chlorination equipment and storage tanks for indications of unusual conditions or problems.
3. Correct problems immediately. Do not wait for results of follow-up samples to take action.

Baxter Well and Distribution System Map

